

Cable ID	Summary	Test Limit	Length	Headroom	Date / Time
RO01-PP01-P01	PASS	TIA Cat 6A PL draft 6.0	20.8 (m)	4.1 dB	13-04-2009 11:36
RO01-PP01-P02	PASS	TIA Cat 6A PL draft 6.0	21.0 (m)	4.2 dB	13-04-2009 11:37
RO01-PP01-P03	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	4.3 dB	13-04-2009 11:38
RO01-PP01-P04	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	2.1 dB	13-04-2009 11:39
RO01-PP01-P05	PASS	TIA Cat 6A PL draft 6.0	18.5 (m)	2.4 dB	13-04-2009 11:39
RO01-PP01-P06	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.9 dB	13-04-2009 11:40
RO01-PP01-P07	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.4 dB	13-04-2009 11:40
RO01-PP01-P08	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.7 dB	13-04-2009 11:41
RO01-PP01-P09	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	4.6 dB	13-04-2009 11:41
RO01-PP01-P10	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.6 dB	13-04-2009 11:42
RO01-PP01-P11	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.9 dB	13-04-2009 11:43
RO01-PP01-P12	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	3.9 dB	13-04-2009 11:44
RO01-PP01-P13	PASS	TIA Cat 6A PL draft 6.0	19.1 (m)	2.7 dB	13-04-2009 11:44
RO01-PP01-P14	PASS	TIA Cat 6A PL draft 6.0	19.1 (m)	4.5 dB	13-04-2009 11:45
RO01-PP01-P15	PASS	TIA Cat 6A PL draft 6.0	20.4 (m)	3.8 dB	13-04-2009 11:46
RO01-PP01-P16	PASS	TIA Cat 6A PL draft 6.0	20.6 (m)	4.8 dB	13-04-2009 11:46
RO01-PP01-P17	PASS	TIA Cat 6A PL draft 6.0	20.4 (m)	4.5 dB	13-04-2009 11:47
RO01-PP01-P18	PASS	TIA Cat 6A PL draft 6.0	20.4 (m)	4.5 dB	13-04-2009 11:47
RO01-PP01-P19	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	2.0 dB	13-04-2009 11:48
RO01-PP01-P20	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	2.2 dB	13-04-2009 11:49
RO01-PP01-P21	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	2.4 dB	13-04-2009 11:49
RO01-PP01-P22	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	4.0 dB	13-04-2009 11:50
RO01-PP01-P23	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	4.6 dB	13-04-2009 11:51
RO01-PP01-P24	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	3.9 dB	13-04-2009 11:51
RO01-PP02-P01	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	2.4 dB	13-04-2009 11:52
RO01-PP02-P02	PASS	TIA Cat 6A PL draft 6.0	20.1 (m)	2.7 dB	13-04-2009 11:52
RO01-PP02-P03	PASS	TIA Cat 6A PL draft 6.0	20.4 (m)	3.2 dB	13-04-2009 11:53
RO01-PP02-P04	PASS	TIA Cat 6A PL draft 6.0	20.6 (m)	4.9 dB	13-04-2009 11:54
RO01-PP02-P05	PASS	TIA Cat 6A PL draft 6.0	20.6 (m)	4.2 dB	13-04-2009 11:54
RO01-PP02-P06	PASS	TIA Cat 6A PL draft 6.0	20.4 (m)	3.8 dB	13-04-2009 11:55
RO01-PP02-P07	PASS	TIA Cat 6A PL draft 6.0	13.2 (m)	3.8 dB	13-04-2009 11:56
RO01-PP02-P08	PASS	TIA Cat 6A PL draft 6.0	13.0 (m)	3.7 dB	13-04-2009 11:57
RO01-PP02-P09	PASS	TIA Cat 6A PL draft 6.0	13.0 (m)	3.3 dB	13-04-2009 11:57
RO01-PP02-P10	PASS	TIA Cat 6A PL draft 6.0	13.0 (m)	3.4 dB	13-04-2009 11:58
RO01-PP02-P11	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.4 dB	13-04-2009 11:59
RO01-PP02-P12	PASS	TIA Cat 6A PL draft 6.0	18.5 (m)	1.8 dB	13-04-2009 11:59
RO01-PP02-P13	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	4.2 dB	13-04-2009 12:00
RO01-PP02-P14	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	1.4 dB	13-04-2009 12:00
RO01-PP02-P15	PASS	TIA Cat 6A PL draft 6.0	26.9 (m)	3.7 dB	13-04-2009 12:01
RO01-PP02-P16	PASS	TIA Cat 6A PL draft 6.0	26.9 (m)	2.9 dB	13-04-2009 12:02
RO01-PP02-P17	PASS	TIA Cat 6A PL draft 6.0	26.2 (m)	1.2 dB	13-04-2009 12:02
RO01-PP02-P18	PASS	TIA Cat 6A PL draft 6.0	26.2 (m)	4.3 dB	13-04-2009 12:06
RO01-PP02-P19	PASS	TIA Cat 6A PL draft 6.0	19.1 (m)	2.9 dB	13-04-2009 12:06
RO01-PP02-P20	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	3.1 dB	13-04-2009 12:07
RO01-PP02-P21	PASS	TIA Cat 6A PL draft 6.0	19.1 (m)	3.5 dB	13-04-2009 12:08
RO01-PP02-P22	PASS	TIA Cat 6A PL draft 6.0	18.9 (m)	4.8 dB	13-04-2009 12:08
RO01-PP02-P23	PASS	TIA Cat 6A PL draft 6.0	29.6 (m)	3.5 dB	13-04-2009 12:09
RO01-PP02-P24	PASS	TIA Cat 6A PL draft 6.0	29.4 (m)	4.3 dB	13-04-2009 12:10
RO01-PP03-P01	PASS	TIA Cat 6A PL draft 6.0	30.2 (m)	4.5 dB	13-04-2009 10:47
RO01-PP03-P02	PASS	TIA Cat 6A PL draft 6.0	29.6 (m)	2.4 dB	13-04-2009 11:10
RO01-PP03-P03	PASS	TIA Cat 6A PL draft 6.0	25.2 (m)	3.1 dB	13-04-2009 10:53
RO01-PP03-P04	PASS	TIA Cat 6A PL draft 6.0	25.0 (m)	3.7 dB	13-04-2009 10:54
RO01-PP03-P05	PASS	TIA Cat 6A PL draft 6.0	15.7 (m)	4.2 dB	13-04-2009 10:55
RO01-PP03-P06	PASS	TIA Cat 6A PL draft 6.0	15.5 (m)	3.1 dB	13-04-2009 11:12
RO01-PP03-P07	PASS	TIA Cat 6A PL draft 6.0	18.5 (m)	3.8 dB	13-04-2009 10:57
RO01-PP03-P08	PASS	TIA Cat 6A PL draft 6.0	18.5 (m)	3.7 dB	13-04-2009 10:57
RO01-PP03-P09	PASS	TIA Cat 6A PL draft 6.0	23.5 (m)	4.2 dB	13-04-2009 10:58
RO01-PP03-P10	PASS	TIA Cat 6A PL draft 6.0	23.5 (m)	4.0 dB	13-04-2009 10:59
RO01-PP03-P11	PASS	TIA Cat 6A PL draft 6.0	21.8 (m)	3.9 dB	13-04-2009 11:00
RO01-PP03-P12	PASS	TIA Cat 6A PL draft 6.0	21.4 (m)	4.3 dB	13-04-2009 11:00
RO01-PP03-P13	PASS	TIA Cat 6A PL draft 6.0	15.5 (m)	2.9 dB	13-04-2009 11:02
RO01-PP03-P14	PASS	TIA Cat 6A PL draft 6.0	21.6 (m)	2.5 dB	13-04-2009 11:03
RO01-PP03-P15	PASS	TIA Cat 6A PL draft 6.0	21.8 (m)	3.7 dB	13-04-2009 11:04
RO01-PP03-P16	PASS	TIA Cat 6A PL draft 6.0	21.8 (m)	2.9 dB	13-04-2009 11:05
RO01-PP03-P17	PASS	TIA Cat 6A PL draft 6.0	21.8 (m)	4.5 dB	13-04-2009 11:05
RO01-PP03-P18	PASS	TIA Cat 6A PL draft 6.0	27.7 (m)	4.0 dB	13-04-2009 11:07
RO01-PP03-P19	PASS	TIA Cat 6A PL draft 6.0	27.3 (m)	1.2 dB	13-04-2009 11:07
RO01-PP03-P20	PASS	TIA Cat 6A PL draft 6.0	27.5 (m)	4.1 dB	13-04-2009 11:08
RO01-PP03-P21	PASS	TIA Cat 6A PL draft 6.0	14.1 (m)	4.1 dB	13-04-2009 11:13
RO01-PP03-P22	PASS	TIA Cat 6A PL draft 6.0	14.3 (m)	2.6 dB	13-04-2009 11:15
RO01-PP03-P23	PASS	TIA Cat 6A PL draft 6.0	15.1 (m)	4.0 dB	13-04-2009 11:22

Cable ID	Summary	Test Limit	Length	Headroom	Date / Time
RO01-PP03-P24	PASS	TIA Cat 6A PL draft 6.0	15.1 (m)	4.0 dB	13-04-2009 11:17
RO01-PP04-P01	PASS	TIA Cat 6A PL draft 6.0	21.0 (m)	4.3 dB	13-04-2009 11:18
RO01-PP04-P02	PASS	TIA Cat 6A PL draft 6.0	21.0 (m)	3.7 dB	13-04-2009 11:18
RO01-PP04-P03	PASS	TIA Cat 6A PL draft 6.0	15.7 (m)	3.6 dB	13-04-2009 11:19
RO01-PP04-P04	PASS	TIA Cat 6A PL draft 6.0	15.9 (m)	5.0 dB	13-04-2009 11:20
RO01-PP04-P05	PASS	TIA Cat 6A PL draft 6.0	15.1 (m)	3.7 dB	13-04-2009 11:21
RO01-PP04-P06	PASS	TIA Cat 6A PL draft 6.0	15.1 (m)	4.2 dB	13-04-2009 11:21
RO01-PP04-P07	PASS	TIA Cat 6A PL draft 6.0	15.9 (m)	2.2 dB	13-04-2009 11:23
RO01-PP04-P08	PASS	TIA Cat 6A PL draft 6.0	16.2 (m)	3.9 dB	13-04-2009 11:23
RO01-PP04-P09	PASS	TIA Cat 6A PL draft 6.0	16.4 (m)	4.3 dB	13-04-2009 11:24
RO01-PP04-P10	PASS	TIA Cat 6A PL draft 6.0	16.6 (m)	4.5 dB	13-04-2009 11:24
RO01-PP04-P11	PASS	TIA Cat 6A PL draft 6.0	16.6 (m)	3.0 dB	13-04-2009 11:25
RO01-PP04-P12	PASS	TIA Cat 6A PL draft 6.0	16.6 (m)	3.5 dB	13-04-2009 11:26
RO01-PP04-P13	PASS	TIA Cat 6A PL draft 6.0	17.6 (m)	3.2 dB	13-04-2009 11:26
RO01-PP04-P14	PASS	TIA Cat 6A PL draft 6.0	18.7 (m)	3.4 dB	13-04-2009 11:40
RO01-PP04-P15	PASS	TIA Cat 6A PL draft 6.0	8.6 (m)	2.9 dB	13-04-2009 11:35
RO01-PP04-P16	PASS	TIA Cat 6A PL draft 6.0	8.8 (m)	2.8 dB	13-04-2009 11:28

Total Length:	1728.0 m
Number of Reports:	88
Number of Passing Reports:	88
Number of Failing Reports:	0
Number of Warning Reports:	0